

VIJAYANAGARA SRI KRISHNADEVARAYA UNIVERSITY, BELLARY.
[ENGINEERING DEPARTMENT]



NO. VSKUB/ENGG/ Quo/B W & L /2025-26/ 1146

Date: 12.02.2026

QUOTATION

Sealed quotations subscribing the name of the For SINKING BORE WELL DRILLING IN THE PREMISES OF VIJAYANAGARA SRI KRISHNADEVARAYA UNIVERSITY, JNANA SAGARA CAMPUS, BALLARI. So as to reach this office on or before 19.02.2026 and quotation should be addressed to Registrar, V.S.K. University, Vinayaknagar, Cantonment, Ballari.

NAME OF WORK:- SINKING BORE WELL DRILLING IN THE PREMISES OF VIJAYANAGARA SRI KRISHNADEVARAYA UNIVERSITY, JNANA SAGARA CAMPUS, BALLARI..

Sl. No	Name of materials / Items or Work	Unit	Quantity	Rate quoted per unit	
				In figures	In words
1.	Sinking borewell of 150mm dia. clear, using super fast hydraulic rig of capacity 250 PSIG & above 900 CMF and above, in all strata of earth, including over burden upto 20M, fixing of casing pipes, collars and cap with necessary cutting, threading and welding including transportation of rig and supporting vehicles, crew charges, cost of consumables, cost of yield test at the final depth with a minimum working of compressor for one hour etc. complete. The cost excludes the cost of casing pipes, collars and caps etc.) for: (Above 300m of drilling add 10% for every 50m depth. (PWD /BWS)CSR 2023-24 VOL 5 BWSSB Page - 139, item no. 12.1.2,12.1.3)	Mtr	170.00		
2.	Providing and installing at site of work P.V.C. pipes including cost of pipes and specials and labour, including lowering into trenches, laying true to line, level and perfect linking at joints leak proof including jointing of approved type with all labour charges and all lift charges, handling charges including encasing the pipe around to a depth not less than 15 cms with gravel or selected earth available from the excavation etc. complete 200mm(weight of pipe - 6.233 kg) (PWD /BWS)CSR 2023-24 VOL 5 BWSSB Page - 120, item no. 10.14.6	Mtr	40.00		
3.	Providing and fixing MS casing collars as per IS 1239 (part-II) 1982 with all latest amendments if any for any dia. The thickness of plate used for covering one end shall be 3mm (minimum). The dimensions of caps and collars shall be strictly as per IS 1239 (Part-II) 1982 with all amendments.(PWD /BWS)CSR 2023-24 VOL 5 BWSSB Page - 143, item no. 12.33	Each	2.00		

4.	Providing and laying at site of work MS casing caps as per IS1239(partII) 1982 with all latest amendments if any for anydia.Thethickness of plate used for covering one end shall be 3mm (minimum). The dimensions of caps and colars shall be strictly as per IS 1239 (Part-II) 1982 with all amendments including cost of material and labour charges for fixing, if any etc. complete with all lead and lifts and as directed by the Engineer in charge..(PWD /BWS)CSR 2023-24 VOL 5 BWSSB Page - 143, item no. 12.34	Each	2.00		
	GST 18% Extra				

I have read the terms and conditions for the above work and I shall abide by the same.

J. Thinnal
12/12/26
REGISTRAR
V.S.K.UNIVERSITY,
BALLARI-583105.
K. D. S. *B. S.*

TERMS & CONDITIONS:

1. The rates quoted should be excluding GST .
2. The right to reject the quotation is vested with University authorities.
3. The quoted rates should be valid at least for 03 months.
4. The rate quoted should be exclusive of GST , transportation, loading & unloading charges etc. complete.

Copy:

- 1) The Director , ICT Department, VSK University, Ballari-583105 for necessary action to upload the quotation in university website for 07 days or up to last date.
- 2) Notice Board.